



ADULT FOSTER HOME FIRE SAFETY INSPECTION
CERTIFICATION AND RECERTIFICATION

Provider Name:		Phone Number:	
Address:		City, State, Zip	
1.	Combustible items are stored at least 3 feet away from sources of heat.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
2.	Home has an annually inspected, approved (2A20BC) fire extinguisher in working order in or near the cooking area of the home.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
3.	Home is equipped with an approved, operating smoke detector on each floor.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
4.	Furnace was inspected and approved by a heating contractor within the past twelve months.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
5.	Electrical wiring is reasonably fire safe.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
6.	Fuse box contains fuses which are of correct amperage.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
7.	Extension cords and flexible cords are used appropriately (eg. Not used as permanent wiring, not affixed to structures, extended through walls, ceiling, floors, under doors or floor coverings or subject to environmental damage or physical impact). Any multiple plug adapters or devices comply with NFPA 70.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
8.	No portable kerosene heaters are in use in the home.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
9.	An evacuation plan is posted in the home and a fire drill is held yearly.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
10.	Resident bedrooms have two means of egress both at least 5.7 square feet and 20 by 24 inches.	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Remarks:			
City conducting fire safety inspection:			
Signature: Fire Safety Inspector and Certification Number			Date